

Facilitating the Technical Network Integration of Distributed PV Generation

While the electricity grid at a food hub can accommodate distributed PV generation, at higher penetration levels there are expected to be impacts caused by voltage rise and variability. Addressing these will allow food-hub operators to plan appropriately and will contribute to the successful technical integration of distributed photovoltaic generation.

### Competitive advantage

- Comprehensive characterisation describing the behaviour of PV generation variability over the course of the day and over the course of the year
- Simple and efficient method for estimating the level of PV generation a low-voltage feeder can accommodate without exceeding upper voltage limits
- Methods for integrating PV systems, controllable loads and other devices, such as electrical storage, to manage distribution voltage levels

# **More Information**

Professor John Fletcher

Energy Systems Research Group, School of Electrical Engineering and Telecommunications

T: +61 (0) 2 9385 6007 E: john.fletcher@unsw.edu.au

UNSW Knowledge Exchange

knowledge.exchange@unsw.edu.au

www.capabilities.unsw.edu.au

+61(2)93855008

### Impact

- Simple and efficient methods for estimating maximum distributed generation capacity of a feeder or microgrid that require no new communication infrastructure and are shown to be more efficient and equitable than similar methods currently proposed
- Rapid assessment and determination of maximum PV generation for distribution feeders
- A novel voltage control method using residential PV systems and controllable loads to ensure voltage levels, upper and lower, are maintained within regulation limits

# Successful applications

• Feeder modelling for distribution operators

# **Capabilities and facilities**

- Software tools to expedite analysis of feeder capability
- Realtime digital simulation facilities to verify models

# **Our partners**

- APVI
- Endeavour Energy